

This information was generated by the HP KEYMARK database on 15 Jun 2021

Summary of	MAB 8-10 v10 240	Reg. No.	041-K012-06
Certificate Holder			
Name	Salvador Escoda S.A.		
Address	Carrer Nàpols 249 Pl.1	Zip	08013
City	Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	MAB 8-10 v10 240		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.65 kg		
Certification Date	21.05.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Model: MAB-8-V10M + HR-8-10-240L-V10M

Configure model	
Model name	MAB-8-V10M + HR-8-10-240L-V10M
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.30 kW	7.50 kW
El input	1.60 kW	2.36 kW
COP	5.20	3.18

Average Climate

This information was generated by the HP KEYMARK database on 15 Jun 2021

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	205 %	132 %
Prated	8.12 kW	6.60 kW
SCOP	5.21	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.19 kW	5.84 kW
COP Tj = -7°C	3.35	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.65 kW	3.76 kW
COP Tj = +2°C	5.09	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.90 kW	2.43 kW
COP Tj = +7°C	6.82	4.34
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 15 Jun 2021

Pdh Tj = 12°C	1.63 kW	1.40 kW
COP Tj = 12°C	8.35	5.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.19 kW	5.84 kW
COP Tj = Tbiv	3.35	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.45 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	1.84
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.68 kW	1.69 kW
Annual energy consumption Qhe	3223 kWh	4056 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

This information was generated by the HP KEYMARK database on 15 Jun 2021

EN 14825

	Low temperature	Medium temperature
η_s	273 %	176 %
Prated	8.12 kW	7.56 kW
SCOP	6.99	4.47
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.57 kW	7.55 kW
COP Tj = +2°C	3.98	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.22 kW	4.86 kW
COP Tj = +7°C	6.26	3.92
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.45 kW	2.32 kW
COP Tj = 12°C	9.02	5.55
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.22 kW	4.86 kW
COP Tj = Tbiv	6.26	3.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	7.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.98	2.59
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 15 Jun 2021

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.55 kW	0.02 kW
Annual energy consumption Qhe	1569 kWh	2259 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	170 %	112 %
Prated	6.98 kW	5.78 kW
SCOP	4.32	2.88
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C

This information was generated by the HP KEYMARK database on 15 Jun 2021

Pdh Tj = -7°C	4.46 kW	3.86 kW
COP Tj = -7°C	3.66	2.48
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.70 kW	2.21 kW
COP Tj = +2°C	5.20	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.66 kW	1.44 kW
COP Tj = +7°C	6.53	4.11
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.47 kW
COP Tj = 12°C	7.96	5.92
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.69 kW	4.71 kW
COP Tj = Tbiv	2.83	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.06 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.95	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 15 Jun 2021

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.91 kW	2.99 kW
Annual energy consumption Q _{he}	3978 kWh	4950 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	5.69	4.71
COP T _j = -15°C (if TOL<-20°C)	2.83	1.90
C _{dh} T _j = -15 °C	0.90	0.90

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	137 %
COP	3.36
Heating up time	2:02 h:min
Standby power input	24.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	171 %
COP	4.18
Heating up time	1:51 h:min
Standby power input	22.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.72
Heating up time	2:18 h:min
Standby power input	24.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l

Model: MAB-10-V10M + HR-8-10-240L-V10M

Configure model	
Model name	MAB-10-V10M + HR-8-10-240L-V10M
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.00 kW	9.50 kW
El input	2.00 kW	3.06 kW
COP	5.00	3.10

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	205 %	137 %
Prated	9.17 kW	7.67 kW
SCOP	5.19	3.49
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.11 kW	6.78 kW
COP Tj = -7°C	3.23	2.24
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.18 kW	4.29 kW
COP Tj = +2°C	5.01	3.42
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.32 kW	2.77 kW
COP Tj = +7°C	7.08	4.52
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 15 Jun 2021

Pdh Tj = 12°C	1.65 kW	1.58 kW
COP Tj = 12°C	8.58	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.11 kW	6.78 kW
COP Tj = Tbiv	3.23	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.40 kW	5.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.96	1.83
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.76 kW	2.28 kW
Annual energy consumption Qhe	3647 kWh	4539 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

This information was generated by the HP KEYMARK database on 15 Jun 2021

EN 14825

	Low temperature	Medium temperature
η_s	279 %	180 %
Prated	8.58 kW	8.63 kW
SCOP	7.12	4.58
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.44 kW	8.06 kW
COP Tj = +2°C	3.84	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.52 kW	5.55 kW
COP Tj = +7°C	6.18	4.10
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.62 kW	2.53 kW
COP Tj = 12°C	9.04	5.82
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.52 kW	5.55 kW
COP Tj = Tbiv	6.18	4.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.44 kW	8.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.84	2.61
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 15 Jun 2021

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.14 kW	0.48 kW
Annual energy consumption Qhe	1628 kWh	2516 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	170 %	116 %
Prated	7.75 kW	6.71 kW
SCOP	4.32	2.99
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C

This information was generated by the HP KEYMARK database on 15 Jun 2021

Pdh Tj = -7°C	4.83 kW	4.27 kW
COP Tj = -7°C	3.60	2.54
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.94 kW	2.57 kW
COP Tj = +2°C	5.26	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.92 kW	1.66 kW
COP Tj = +7°C	7.08	4.37
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.48 kW
COP Tj = 12°C	7.96	5.96
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.32 kW	5.48 kW
COP Tj = Tbiv	2.64	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.63 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.13 kW	3.91 kW
Annual energy consumption Q _{he}	4424 kWh	5540 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	6.32	5.48
COP T _j = -15°C (if TOL<-20°C)	2.64	2.00
C _{dh} T _j = -15 °C	0.90	0.90

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	137 %
COP	3.36
Heating up time	2:02 h:min
Standby power input	24.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	171 %
COP	4.18
Heating up time	1:51 h:min
Standby power input	22.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.72
Heating up time	2:18 h:min
Standby power input	24.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	275 l